

ASi-3 BACnet/IP Gateway in Stainless Steel

Recognition of Duplicate ASi Addresses

ASi Earth Fault Detector integrated


ASi Noise Detector integrated

Optional Control III, programming in C



(figure similar)



| Figure | Type | Model | Fieldbus interface ⁽¹⁾ | Number of ASi networks, number of ASi Master ⁽²⁾ | 1 power supply, 1 gateway for 2 ASi networks, inexpensive power supplies ⁽³⁾ | Diagnostic and configuration interface ⁽⁴⁾ | Recognition of duplicate ASi addresses ⁽⁵⁾ | ASi fault detector ⁽⁶⁾ | Programming in C ⁽⁷⁾ | Article no. |
|--|---------------|---------|-----------------------------------|---|---|---|---|-----------------------------------|---------------------------------|----------------|
|  | BACnet/IP ASi | Gateway | BACnet/IP | 2 ASi networks, 2 ASi Masters | no, max. 8 A/ ASi network, redundant supply | Ethernet Fieldbus + Ethernet diagnostic | yes | yes | optional | BWU3356 |

(1) **Fieldbus interface**

Communication interface between fieldbus and gateway: interfaces for standardized fieldbus systems in industrial automation.

BACnet/IP Gateway: interface for a BACnet fieldbus

(2) **Number of ASi networks, number of ASi Master**

"Double Master": 2 ASi networks, 2 ASi Masters.

(3) **1 power supply, 1 gateway for 2 ASi networks, inexpensive power supplies**

"no, max. 8 A/ASi network, redundant supply": 1 power supply per ASi network. Gateway is powered in normal operation from one of the two ASi power supplies. Should one ASi power supply fail, switching to the other ASi power supply allows all the diagnostics functions to be maintained and the unaffected ASi network continues to operate.

(4) **Diagnostic and configuration interface**

"Ethernet fieldbus + Ethernet diagnostic": Access to ASi Master and Safety Monitor with Bihl+Wiedemann software by using the Ethernet diagnostic interface or Ethernet fieldbus interface.

The latest version of the device description file of the gateway is available in the "Downloads" section of the respective device.

(5) **Recognition of duplicate ASi addresses**

Detects whether the same address has been assigned to two ASi slaves. Frequent error when using a hand held addressing device.

(6) **ASi fault detector**

Checks the ASi line for interference effects such as noise, external voltages, etc.

(7) **Programming in C**

Using a C-program offers the possibility to run mini-PLC functions with a gateway.

ASi-3 BACnet/IP Gateway in Stainless Steel

| | |
|---|--|
| Article no. | BWU3356 |
| Interface | |
| Ethernet interface | 1 x RJ-45, acc. IEEE 802.3 BACnet/IP acc. EN ISO 16484-5 |
| Baud rate | 100 MBaud |
| Card slot | Chip card for storage of configuration data |
| ASi | |
| ASi specification | 3.0 |
| Cycle time | 150 µs * (number of slaves + 2) |
| Operating voltage | 30 V _{DC} (20 ... 31,6 V) (PELV voltage) |
| Display | |
| LCD | menu, ASi indication of slave addresses, error messages in plain text |
| LED power (green) | power ON |
| LED net (green) | BACnet communication active |
| LED config error (red) | configuration error |
| LED U ASi (green) | ASi voltage o.k. |
| LED ASi active (green) | ASi normal operation active |
| LED prg enable (green) | automatic slave programming enabled |
| LED prj mode (yellow) | configuration mode active |
| UL-specifications (UL508) | |
| External protection | An isolated source with a secondary open circuit voltage of ≤30 V _{DC} with a 3 A maximum over current protection. Over current protection is not required when a Class 2 source is employed. |
| In general | UL mark does not provide UL certification for any functional safety rating or aspects of the above devices. |
| Environment | |
| Applied standards | EN 60529 EN 61000-6-2 EN 61000-6-4 |
| Operating altitude | max. 2000 m |
| Operating temperature | 0 °C ... +55 °C |
| Storage temperature | -25 °C ... +85 °C |
| Housing | Stainless Steel, for DIN rail mounting |
| Protection category | IP20 |
| Tolerable loading referring to impacts and vibrations | according to EN 61131-2 |
| Voltage of insulation | ≥500 V |
| Weight | 500 g |
| Dimensions (W / H / D in mm) | 85 / 120 / 83 |

| Article no. | Operating current | | |
|----------------|---|---|--|
| | Master power supply, max. 200 mA out of ASi circuit 1 (ca. 70 mA ... 200 mA), max. 200 mA out of ASi circuit 2 (ca. 70 mA ... 200 mA); in sum max. 270 mA | Version „1 gateway, 1 power supply for 2 ASi networks“, approx. 250 mA (PELV voltage) | Master power supply, ca. 200 mA out of ASi circuit |
| BWU3356 | • | - | - |

ASi-3 BACnet/IP Gateway in Stainless Steel

| Article no. | BWU3356 |
|--|---------|
| Redundant power supply out of ASi: all fundamental functions of the device remain available even in case of power failure in one of the two ASi networks | • |
| Current measurement of the ASi circuits | – |
| Self-resetting adjustable fuses | – |
| ASi earth fault monitor distinguishes between ASi cable and sensor cable | – |
| In version 1 gateway, 1 power supply for 2 ASi circuits: only 1 Gateway + 1 ASi power supply for 2 ASi networks | – |

Accessories:

- Bihl+Wiedemann Suite - Software for Configuration, Diagnostics and Commissioning (art. no. BW2902)
- Power supplies, e.g.: ASi power supply, 4 A (art. no. BW1649), ASi power supply, 8 A (art. no. BW1997)
(further power supply units can be found at www.bihl-wiedemann.de/en/products/accessories/power-supplies)